

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.2883574/24

Dated : 14.01.2025

It is certified that an inspection headed by Health Squad from TRIPUNITHURA MUNICIPALITY inspected the Bhavan's Munshi Vidyashram, Old Guest House Road, Thiruvamkulam, Tripunithura, Kerala-Pin-682305 on 13.01.2025 and found that the Bhavan's Munshi Vidyashram has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per norms prescribed by the Central/State/U.T Govt.

The above is valid for a period of 1 year.



Signature with Seal.....*[Handwritten Signature]*.....14.1.2025

NameSANJEEV KUMAR.S.....

DesignationClean City Manager
.....Tripunithura Municipality.....

Name & Address of the Office/Department.....

To

Bhavan's Munshi Vidyashram
Old Guest House Road
Thiruvamkulam,
Tripunithura, Pin-682305


[Handwritten Signature]
15/1/25

LATHA S
PRINCIPAL


Bhavan's Munshi Vidyashram
Tripunithura, Pin-682 305

[Handwritten Signature]

MANAGER
BHAVANS MUNSHI VIDYASHRAM,
THIRUVAMKULAM, TRIPUNITHURA
KOCHI-682305



TC-6793



GOVERNMENT OF KERALA

REGIONAL ANALYTICAL LABORATORY
KAKKANAD, ERNAKULAM, PIN – 682030.
E-mail: regionalanalyticallabernakulam@gmail.com

TEST REPORT

Report No.10987/A/24-25

ULR No:TC67932400004378F

Issue Date. 16.12.2024

Particulars of the sample : Drinking Water (Kerala Water Authority)	Name & Address of Customer : Bhavan's Munshi Vidyashram, Thiruvamkulam, Tripunithura – 682305 (Sample forwarded by Medical Officer In Charge, Family Health Centre, Thiruvamkulam)
Date of receipt of sample : 03.12.2024	
Date of Analysis : 07.12.2024 – 16.12.2024	
Condition of Sample : Fit for Analysis	Sample Quantity received : 2 L+ 125 ml
Sample Description : Clear liquid with sediments having agreeable odour	Type of packing : Plastic Can + Sterile Bottle

CHEMICAL TESTING

Sl No.	Parameters	Test Method	Unit	Result	Acceptable Limit as per IS 10500 : 2012 (With Amendment No. 1, 2, 3 & 4)
1.	pH value	FSSAI Manual of Methods of Analysis of Foods-Water, 2016	--	6.77	6.5-8.5
2.	Turbidity	FSSAI Manual of Methods of Analysis of Foods-Water, 2016	NTU	1.00	Max. 1.0
3.	Total Alkalinity (as CaCO ₃)	FSSAI Manual of Methods of Analysis of Foods-Water, 2016	mg/l	16.88	Max. 200
4.	Total Hardness(as CaCO ₃)	APHA,2340 ,24 th Edition	mg/l	16.08	Max. 200
5.	Calcium (as Ca)	APHA,3500 Ca,24 th Edition	mg/l	4.83	Max. 75
6.	Magnesium (as Mg)	APHA ,3500 Mg, 24 th Edition	mg/l	0.98	Max. 30
7.	Sulphates (as SO ₄)	Official Methods of AOAC, Volume I, Method No: 973.57, 22 nd Edition	mg/l	Below LOQ (LOQ = 10 mg/l)	Max. 200
8.	Fluoride (as F)	APHA,4500-F'D, 24 th Edition	mg/l	Below LOQ (LOQ = 0.2mg/l)	Max. 1.0
9.	Chloride (as Cl)	FSSAI Manual of Methods of Analysis of Foods-Water, 2016	mg/l	8.87	Max. 250
10.	Nitrate (as NO ₃)	APHA,4500 NO ₃ B,24 th Edition	mg/l	4.49	Max. 45
11.	Total Dissolved Solids	FSSAI Manual of Methods of Analysis of Foods-Water, 2016	mg/l	55.00	Max. 500
12.	Iron (as Fe)	APHA 3500 Fe B,24 th edition	mg/l	0.74	Max. 1.0
13.	Ammonia (as total ammonia - N)	APHA 4500 NH ₃ F, 24 th edition	mg/l	Below LOQ (LOQ = 0.1 mg/l)	Max. 0.5


LOQ = Limit of Quantification

Opinion: Satisfactory

Note:

1. The test report relates to the tested parameters and to the tested item (as received) only.
2. The report shall not be reproduced except in full with the approval of the Laboratory.
3. In Test report the decision rule of the laboratory is applied and when required.
4. The complete report includes both A and B reports.

Lathi
15/12/25
LATHIAS
PRINCIPAL
Bhavan's Munshi Vidyashram
Tripunithura - Pin-682-305



Ruby Mathew
Ruby Mathew
Authorized Signatory

Seetha
MANAGER
BHAVANS MUNSHI VIDYASHRAM
THIRUVAMKULAM, TRIPUNITHURA
KOCHI-682305

-End of the Report-



GOVERNMENT OF KERALA


REGIONAL ANALYTICAL LABORATORY
KAKKANAD, ERNAKULAM, PIN - 682030.
E-mail: regionalanalyticalabernakulam@gmail.com

TEST REPORT

Report No.10987/B/24-25

Issue Date. 16.12.2024


Particulars of the sample Drinking Water (Kerala Water Authority)		Name & Address of Customer: Bhavan's Munshi Vidyashram, Thiruvankulam, Tripunithura – 682305 (Sample forwarded by Medical Officer In Charge, Family Health Centre, Thiruvankulam)			
Date of receipt of sample : 03.12.2024		Sample Quantity received : 2 L+ 125 ml			
Date of Analysis : 07.12.2024 – 16.12.2024		Type of packing : Plastic Can + Sterile Bottle			
Condition of Sample : Fit for Analysis					
Sample Description : Clear liquid with sediments having agreeable odour					
MICROBIOLOGICAL TESTING					
Sl No.	Parameters	Unit	Test Method	Result	Acceptable Limit as per IS 10500 : 2012 (With Amendment No. 1, 2, 3 & 4)
1.	Coliforms	MPN/100 ml	IS 1622 1981 RA 2019	<2	Less than 2
2.	E.Coli	--	IS 1622 1981 RA 2019	Absent/100ml	Shall be absent


Ruby Mathew
Authorized Signatory

Note:

1. The test report relates to the tested parameters and to the tested item (as received) only.
2. The report shall not be reproduced except in full without approval of the Laboratory.
3. In Test report the decision rule of the laboratory is applied as and when required.
4. The complete report includes both A and B reports

-End of the Report-


MANAGER
BHAVANS MUNSHI VIDYASHRAM
THIRUVANKULAM, TRIPUNITHURA
KOCHI-682305


15/11/25
LATHA S
PRINCIPAL
Bhavan's Munshi Vidyashram
Tripunithura, Pin-682 305